

SECTION 7

7.03 EXCAVATION TO LINE AND GRADE:

All excavations shall be made to the lines and grades as established by the approved drawings. Pipe trenches shall be excavated to a minimum depth of 6 inches below the bottom of the pipe. Deviation from grades will be allowed when approved by Denver Water, in accordance with 8.06 and 8.07.